

# LAKESHORE FIRE DEPARTMENT

## Hydrant Colour Coding



Hydrant Class	Colour	Flow
AA	BLUE	1,500 gpm (5,678 L/min) or greater
A	GREEN	1,000 - 1,499 gpm (3,785 L/min - 5,677 L/min)
B	ORANGE	500 - 999 gpm (1,893 L/min - 3,784 L/min)
C	RED	less than 500 gpm (1,893 L/min)



The hydrant's BONNET and 2.5" Diameter Caps are to be painted according to the flow results as determined by a qualified service provider. Hydrants not provided with a STORZ CONNECTION will also have their 4" cap painted.

**Ontario Fire Code 6.6.6 - Uniform Marking of Hydrants - Hydrant Marking 6.6.6.1., Hydrants shall be colour-coded in accordance with NFPA 291, "Recommend Practice for Fire Flow Testing and Marking of Hydrants"**